

RULES

FOR THE CLASSIFICATION AND CONSTRUCTION OF FIXED OFFSHORE PLATFORMS

ND No. 2-020201-027-E

RULE CHANGE NOTICE

ENTERS INTO FORCE:

01.01.2025



St. Petersburg
2024

RULES FOR THE CLASSIFICATION AND CONSTRUCTION OF FIXED OFFSHORE PLATFORMS

The present Rule Change Notice to the Rules for the Classification and Construction of Fixed Offshore Platforms (the FOP Rules) has been approved in accordance with the established approval procedure and contains information on amendments and additions, except for editorial amendments. RCN amendments come into force on 1 January 2025.

REVISION HISTORY

PART VI. FIRE PROTECTION

Item	Applicability	Description	Remarks
Para 3.1.7 (new)	Fixed offshore platforms (FOP) Gas fire extinction stations Device for control of gas fire extinguishing medium mass in cylinders	Requirement has been introduced for methods of determining gas fire extinguishing medium mass in cylinders in the FOP gas fire extinction stations	

PART VI. FIRE PROTECTION

3 FIRE-FIGHTING EQUIPMENT AND SYSTEMS

3.1 GENERAL

New para 3.1.7 is introduced reading as follows:

"3.1.7 In the gas fire extinction stations, a device shall be provided for weighing cylinders or measuring level of gas extinguishing medium therein by the approved method, or on each cylinder an automatic device shall be installed for control of gas extinguishing medium mass and pressure (recommended for unmanned FOP).".

Russian Maritime Register of Shipping

**Rule Change Notice
to the Rules for the Classification and Construction
of Fixed Offshore Platforms**

Endorsed: 24-212585

FAI "Russian Maritime Register of Shipping"
7, Litera A, Millionnaya Ul.,
191181, St. Petersburg, Russian Federation
www.rs-class.org/en/